

LONDON BOROUGH OF ENFIELD

PLANNING COMMITTEE

Date : 23rd February 2016

Report of

Assistant Director, Planning &
Environmental Protection

Contact Officer:

Andy Higham Tel: 020 8379 3848
Kevin Tohill Tel: 020 8379 3841
Ray Reilly Tel: 020 8379 3579

Ward: Edmonton
Green.

Application Number : 15/04736/FUL

LOCATION: 2A / 2B Park Avenue London N18 2UH

PROPOSAL: Demolition of existing warehouse and erection of a part 3, part 4 storey block to provide 14 flats (comprising 4x3bed, 7x2 bed, 3x1 bed flats), with associated cycle/refuse storage and landscaping.

Applicant Name & Address:


Magic Home Ltd.
7-11 Green Lanes,
London,
N13 4TN.

Agent Name & Address:

Peter Ottery
112 southbury road
Enfield
EN1 1YE

RECOMMENDATION: That planning permission be **GRANTED** subject to conditions and completion of a S106 Agreement.

Ref: 15/04736/FUL LOCATION: 2A / 2B Park Avenue, London, N18 2UH,



Reproduced by permission of Ordnance Survey on behalf of HMSO. ©Crown Copyright and database right 2013. All Rights Reserved. Ordnance Survey License number 100019820

Scale 1:1250

North



1. Site and surroundings

- 1.1 The application site is located on the corner of Park Avenue and Park Road and is addressed as 2A/2B Park Avenue. The site currently consists of an original warehouse building of 2 storeys in height with a triple apex roof. At present the site appears to have been broken up into three individual units. The unit on the outside is derelict; the middle unit which appears to be occupied by a Christian church group and a 2 storey warehouse/lock up appears to make up the third unit. Having analysed the Council planning records there appears to be no planning permission for the use of the site for the Christian group.
- 1.2 The surrounding area is mixed in nature, there is a hostel to the west of the building (under the same ownership), to the north opposite on Park Road is a derelict site although this site has planning permission for a development of 18 units. To the east opposite on Park Avenue are two storey houses and to the south lies a series of industrial uses and car mechanic garages.
- 1.3 The site is not located in a Conservation Area and is not listed. The site has a PTAL rating of 5 and is not located within a controlled parking zone.

2. Proposal

- 2.1 The applicant seeks full planning permission for the demolition of the existing buildings on the site and the erection of a part 3, part 4 storey building to accommodate 14 flats (comprising 4 x 3- bed, 7 x 2- bed and 3 x 1 –bed). The building would be 9m high to third floor level and 12m high to fourth floor level. The building would be 26.5m wide and approximately 16m deep. It would consist of a modern design with buff brick with the 4th floor a recessed rendered finish. The windows are proposed as grey aluminium and the design would also include for balconies and terraces.
- 2.2 The application also includes the provision of 3 on site car parking spaces and 28 cycle parking spaces. The building is to be proposed in a mixture of buff brick, render, glazed balconies and aluminium materials.

3. Relevant planning history

- 3.1 P12-00581PLA: Conversion of 9 supported living units into 12 self-contained studio flats for social housing. Withdrawn.
- 3.2 14/04851/FUL: Demolition of existing vacant warehouse and erection of a 3-storey block of 12 self-contained flats. Withdrawn.
- 3.3 P15-02002-FUL: Demolition of existing warehouse and erection of a part 3 storey, part 4 storey block to provide 14 flats (comprising 2 x 3- bed, 9 x 2- bed and 3 x 1 -bed) with associated car parking, cycle/refuse storage and landscaping.

This application was refused for the following reasons:

1. The proposed development is an overdevelopment of the site with specific reference to the dominant scale and positioning of the proposed 4th storey. In addition the poor design and integration of the proposed building with the

hostel building on the site and the poor design appearance of the eastern elevation of the building facing Park Avenue overall would lead to the introduction of a building which through its resultant prominence and discordant form, would be detrimental to the pattern, visual amenities general appearance of the locality. This would be contrary to policies CP30 of the Core Strategy, 3.4, 7.4 and 7.6 of the London Plan (Revised Early Minor Alterations) and DMD6 and DMD37 of the Development Management Document as well as the guidance contained within the NPPF.

2. The provision of only 2 family sized units of the total 14 units proposed would represent a very poor provision of family accommodation on the site and overall would lead to a poor mix of residential accommodation within the development. This would be contrary to policies DMD3 of the Development Management Document and CP5 of the Councils Core Strategy.
3. The application has not robustly justified the failure to provide a suitable mechanism to secure financial contributions towards off site education and infrastructure provisions, contrary to Policies 8 and 46 of the Local Plan as well as the requirements outlined in the Local Authority's S106 Supplementary Planning Document.
4. Insufficient detail has been submitted to enable the Local Planning Authority to accurately assess the credentials of the scheme against the Code for Sustainable Homes with an objective to meet a minimum of Code Level 4. In this regard, the development fails to take into account the principles of sustainable design and construction contrary to Core Policy 4 of the Core Strategy, DMD 50 of the Development Management Document and Policies 5.2 & 5.3 of the London Plan as well as the National Planning Policy Framework.

Other Relevant Planning History:

- 3.4 14/02467/FUL: *10 Park Road (Site Opposite)* Erection of a four storey block comprising 18 self-contained flats (7 x 1-bed, 7 x 2-bed, 4 x 3-bed) with balconies, amenity area, associated access via Park Road and surface car parking. S106 - S106 Granted with conditions.

4. Consultation

Public Consultations

- 4.1 The 21 day public consultation period started on the 23rd of October and concluded on the 13th of June. 3 Site notice were posted close to the site on 28th of October. The application was also advertised in the local paper. There were no comments received from any members of the public.

Internal

- 4.2 Traffic and Transportation - No objections subject to conditions and S106 obligations to mitigate against parking impacts in the surrounding area.
- 4.3 Environmental Health - No objections subject to conditions
- 4.4 Housing Officer - A minimum of 6 units should be provided towards affordable housing, 4 as social or affordable rent and 2 as intermediate.

External

- 4.5 Thames Water - no objection raised.
- 4.6 Environment Agency - no objections raised.

5. Relevant Policy

5.1 Development Management Document

| | |
|-------|---|
| DMD1 | Affordable Housing on site capable of providing 10 or more units. |
| DMD3 | Providing a Mix of Different Sized Homes |
| DMD6 | Residential Character |
| DMD7 | Development of garden land |
| DMD8 | General Standards for New Residential Development |
| DMD9 | Amenity Space |
| DMD10 | Distancing |
| DMD37 | Achieving High Quality and Design-Led Development |
| DMD47 | New Roads, Access and Servicing |
| DMD49 | Sustainable Design and Construction Statements |
| DMD50 | Environmental Assessment Methods |
| DMD51 | Energy Efficiency Standards |
| DMD64 | Pollution Control and Assessment |
| DMD68 | Noise |
| DMD69 | Light Pollution |
| DMD76 | Wildlife Corridors |
| DMD77 | Green Chains |
| DMD78 | Nature Conservation |

5.2 Core Strategy

| | |
|-------|---|
| SO2 | Environmental sustainability |
| SO4 | New homes |
| SO5 | Education, health and wellbeing |
| SO8 | Transportation and accessibility |
| SO10 | Built environment |
| CP2 | Housing supply and locations for new homes |
| CP3 | Affordable housing |
| CP4 | Housing quality |
| CP5 | Housing types |
| CP6 | Meeting particular housing needs |
| CP8 | Education |
| CP9 | Supporting community cohesion |
| CP16 | Taking part in economic success and improving skills |
| CP20 | Sustainable energy use and energy infrastructure |
| CP21 | Delivering sustainable water supply, drainage and sewerage infrastructure |
| CP22 | Delivering sustainable waste management |
| CP24 | The road network |
| CP25 | Pedestrians and cyclists |
| CP30 | Maintaining and improving the quality of the built and open environment |
| CP32: | Pollution |
| CP36 | Biodiversity |
| CP46 | Infrastructure Contribution |

5.3 London Plan (2015) (including REMA)

- 3.3 Increasing housing supply
- 3.4 Optimising housing potential
- 3.5 Quality and design of housing development
- 3.6 Children and young people's play and informal recreation facilities
- 3.8 Housing choice
- 3.9 Mixed and balanced communities
- 3.10 Definition of affordable housing
- 3.11 Affordable housing targets
- 3.12 Negotiating affordable housing on schemes
- 3.13 Affordable housing thresholds
- 4.1 Developing London's economy
- 4.4 Managing industrial land and premises
- 5.1 Climate change mitigation
- 5.2 Minimising carbon dioxide emissions
- 5.3 Sustainable design and construction
- 5.7 Renewable energy
- 5.8 Innovative energy technologies
- 5.10 Urban greening
- 5.11 Green roofs and development site environs
- 5.13 Sustainable drainage
- 5.14 Water quality and wastewater infrastructure
- 5.15 Water use and supplies
- 5.16 Waste self sufficiency
- 6.3 Assessing the effects of development on transport capacity
- 6.9 Cycling
- 6.12 Road network capacity
- 6.13 Parking
- 7.1 Building London's neighbours and communities
- 7.2 An inclusive environment
- 7.3 Designing out crime
- 7.4 Local character
- 7.5 Public realm
- 7.6 Architecture
- 7.19 Biodiversity and access to nature
- 7.21 Trees and Woodland

5.4 Other Relevant Policy

- National Planning Policy Framework

5.5 Other Material Considerations

- The Mayors Housing SPG (2012)
- Section 106 Supplementary Planning Document (Nov.2011)
- Enfield Strategic Housing Market Assessment (2010)

6. Analysis

6.1 The main issues for consideration regarding this application are as follows:

- Principle of the Development;
- Scale and Density;

- Design and Impact on the Character of the Surrounding Area;
- Neighbouring Amenity;
- Standard of Accommodation and Proposed Mix of Units;
- Private Amenity provisions;
- Traffic, Parking and Servicing Issues;
- Affordable Housing and other S106 Contributions;
- Sustainability;
- Tree Issues.

6.2 Principle of the Development

6.2.1 There were no objections raised to the principle of the redevelopment of the site on the previous applications. The principle of the development would be supported insofar as the proposal provides for additional housing in the borough of which there is an identified need. The proposed site is in a relatively accessible location with a PTAL of 5 and as such additional housing should be encouraged in such locations.

6.2.2 Similar to the previous applications, there has been relatively little information submitted with regards the use of the current site and whether the loss of the current employment use would be suitable. However officers have assessed the case on site and taking into account the relatively dilapidated appearance of the site it is considered that the redevelopment to provide additional residential units for the area would be the better use of the site.

6.2.3 In addition since the previous submissions the scheme has been significantly improved. From the perspective of design and bulk it is much less top heavy than the previous scheme with specific regard to the scale and form of the top floor. This is now much more recessed and subordinate to the 3 storey section of the building. In addition through negotiations with the applicant 4 family units are now to be provided as part of the scheme which is considered suitable taking into account the relative confines of the site and its practicality to accommodate family housing. The applicant has also agreed upon S106 contributions towards Affordable Housing, Education and local Highways work with the councils appointed viability assessor. These issues will all be referred to in greater detail later in the report.

6.3 Density and Scale

Density

6.3.1 Density assessments must acknowledge new guidance outlined in the NPPF and particularly the London Plan, which encourage greater flexibility in the application of policies to promote higher densities, although they must also be appropriate for the area.

6.3.2 Policy 3.4 (Table 3.2) of the London Plan sets standards for appropriate density levels with regards to location, existing building form, massing, and having regard to the PTAL (Public Transport Accessibility Level) score. From assessing the plans it is considered a total of 40 habitable rooms would be provided on the site which is of approximately 0.054 hectares. According to the guidance in (Table 3.2) of the London Plan as the site has a site specific PTAL rating of 5 in an urban location, an overall density of between 200-700 hr/ha may be acceptable. Upon calculating the density of the proposed

development against this density matrix, based on habitable rooms per hectare this development would equate to 740 hr/ha.

6.3.3 Therefore these results show that from a density perspective this proposal would be slightly in excess of the recognisable density threshold for the area.

6.3.4 However, it must be noted that the criteria of density would not be a singular element and would be assessed alongside other planning requirements such as suitability of the site, scale of building/s and standard and quality of accommodation proposed. In this case due to the tightness of the site neighbouring amenity would also be a primary consideration.

6.4 Scale, Design Character and Impact on the Surroundings

6.4.1 As referred to earlier the building is proposed as: part 3, part 4 storey in height, 26.5m wide and 16.5m deep. It would be set against the existing hostel building which is 2 storey in height and the building would back onto single storey industrial buildings at the rear. Opposite on Park Avenue are 2 storey houses and due regard has been given to the fact that the site opposite on Number 10 Park Road has been granted planning consent for a part 3, part 4 storey building.

6.4.2 Similar to the previous submission ref: P15-02002-FUL from the perspective of scale it is considered that the principle of a part 3, part 4 storey is acceptable on the site. This would largely replicate the scale and height of the scheme that has been granted across the road at Number 10.

6.4.3 There were a number of issues that were raised as concerns on the previous application, mainly in relation to the bulk, scale and prominence of the fourth floor and the lack of fenestration and orientation of the scheme onto Park Avenue.

6.4.4 On this submission the proposed 4th floor is recessed in approximately 2m behind the main parapet wall on all elevations particularly so on the front and side elevations which are most prominent on the Park Road and Park Avenue. This has been achieved by reducing the number of flats at 4th floor level and re-accommodating one flat at ground level. As a result the proposed 4th floor is now much more subordinate and as a result of its reduced bulk and scale would be much less dominant. Having re-assessed the proposal on site officers consider that the proposal has been sufficiently reduced in scale to be deemed acceptable. In addition the introduction of additional fenestration onto the Park Avenue elevation to complement the front Park Road elevation has introduced an additional element of visual interest and overall a much more balanced appearance to the development.

6.4.5 Due regard should be given to the permission granted on the opposite side of Park Road at Number 10 and having assessed this proposal in line with that permission it is considered that both developments would complement each other. In conclusion from the design scale and character this proposed development is considered acceptable as it would integrate acceptably into the adjoining Park Road/ Park Avenue streetscene having regard to policies DMD6, 8 and 37, CP30 of the Core Strategy and London Plan policies 7.4 and 7.6.

6.5 Neighbouring Amenity

6.5.1 From the perspective of neighbouring amenity, it is considered the proposal should be assessed against the following properties,

- Houses opposite on Park Avenue.
- Adjacent Hostel at Number 2A.
- New Development opposite on Number 10 Park Avenue.
- Industrial premises to the rear

Houses opposite on Park Avenue

6.5.2 The site sits directly opposite to Numbers 27 to 37 Park Avenue which would be most affected by the development proposals. The proposed building is set hard on the eastern edge of the site (back of the public footpath) and therefore the proposed building would have a separation distance of approximately 17.5 to 18m from the front elevation of the houses at Number 27 to 37 Park Avenue. The recessed 4th floor would represent a separation distance of 22m between the houses on Number 27-37 Park Avenue.

6.5.3 With respect to distancing standards it is recognised that this is below the requirements of DMD 10 which in such circumstances would specify a distance of at least 25m. However this refers to rear windows and in this case it must be acknowledged that the windows would be looking out onto and across a public highway. Officers have assessed the proposal externally from within the front gardens of Number 37 and whilst the new building would create an obvious additional dominance when viewed across the street, it is not considered that it would create such an impact to warrant refusal. In addition to this it should be noted that the proposed building would not break a 25 degree line of site towards the sky from the ground floor windows of the houses opposite on Park Avenue, therefore would be acceptable in principle from the perspective of Daylight and Sunlight BRE guidance.

Adjacent Hostel at 2A

6.5.4 As referred to earlier there is a hostel directly adjacent the application site. It sits directly west of the site between the western boundary and the railtrack further west.

6.5.5 From the perspective of neighbouring amenity it is considered the proposed development will have an acceptable impact onto the adjoining hostel. At present to the front the two storey warehouse building sits approximately 6m forward of the building line and the nearest adjacent windows on the hostel. By comparison the proposed building would be sited 4.5m forward of this building line and increase to a part 3 part 4 storey height. Whilst this would create additional bulk laterally it is not considered that it would not create a significant degree of additional harm in terms of blocking outlook from those north most facing front windows. In addition as the windows are north facing it is also not considered that it would create a significant impact in terms of loss of daylight and sunlight.

6.5.6 Officers consider that the neighbouring amenity situation would improve with the demolition of the existing rear two-storey warehouse building to be replaced by rear gardens.

New Development opposite on Number 10 Park Road

6.5.7 A planning application has been granted at Number 10 Park Road opposite under planning approval ref: 14/02467/FUL. This development granted consent for 18 flats within a 4 storey building. From assessing the proposed plans the distance between this scheme and that granted scheme would be approximately 18-19 metres across the Park Road. Again this is a similar relationship to those houses on Park Avenue. However having assessed the surrounding area, this is a relatively established separation distance and overall officers consider that this distance would provide for a sufficient level of separation and distances between both blocks. In addition to this it should be noted that the proposed building would not break a 25 degree line of site towards the sky from the ground floor windows of the houses opposite on Park Avenue, therefore would be acceptable in principle from the perspective of Daylight and Sunlight BRE guidance.

Industrial Premises to the rear

6.5.8 To the rear of the site lies a car mechanics yard and industrial buildings. Having assessed the proposal against these buildings it is not considered that there would not be any neighbouring amenity impacts. The premises are business uses with no residential uses on site.

6.5.9 It is recognised that the proposed site with the rear facing windows could have potential implications for development on the site to the rear in the future, however this is not considered to be a sufficient reason to refuse this current application at this stage. It is considered that any privacy impact as a result of the proposed scheme on a future scheme to the rear would need to be addressed on any future submission via angled or obscured windows on that site.

6.5.10 In conclusion, all factors considered the proposal has an acceptable impact in terms of neighbouring amenity to all adjoining occupiers.

6.6 Standard of Accommodation and Proposed Mix of Units

Standard of Accommodation

6.6.1 The application proposes 3x1bed, 7x2 bed and 4x3 bed flats, 14 in total.

6.6.2 Policy 3.5 of the London Plan specifies that 1 bed flats should a minimum floor area of 50sqm, 2 bed flats should have a minimum internal floor area of 61 square metres with 3b4p flats at 74 sqm or 3b6p flats at 86 sqm. All units have been measured and verified and are above the required London Plan standards for the respective units. From assessing the plans all units would have useable and accessible layouts and all room sizes are acceptable with specific regards to living/diners and single and double bedrooms. All units would be dual aspect. It is recognised that there are units on the ground floor relatively close to the boundary, however having assessed the situation on site it is considered on balance that all units would have sufficient defensible space. Flat 1 on the corner is the most exposed but specifically only in relation to the rear terrace. A condition will be assigned to any approval requesting final details of how this terrace is to be secured from the public highway.

- 6.6.3 There are currently no wheelchair accessible units proposed as part of the development, however the flats on the ground floor could be adapted to all be wheelchair accessible, therefore it is considered that this could be dealt with by an appropriate condition.

Housing Mix

- 6.6.4 DMD 3 and Policy 5 of the Core Strategy seeks new development to incorporate a mix of dwelling types and sizes to meet housing needs in the Borough with family sized accommodation (3 bed or larger) is the greatest area of need.

- 6.6.5 The Council's dwelling mix ratios are as follows:

- 1 and 2 person flats - 20%
- 2 bed flats - 15%
- 3 bed houses - 45%
- 4 + bed houses - 20%

- 6.6.6 The development provides the following dwelling mix:

- 3 no.1b 2p (21.5%)
- 7 no.2b 3p (and) 4p (combined 50%)
- 4no. 3b 4 or 5p (28.5%)

- 6.6.7 One of reason for refusal on the previous application was the insufficient amount of family units proposed as part of the scheme. On that submission there were only 2 family units proposed out of the total of 14. In addition there was no justification submitted to justify the lack of more family units.

- 6.6.8 Since the previous refusal officers have had a number of discussions with the applicant in relation to the scheme and it has been agreed that the scheme could viably provide 4 family units. 1 of these units would be located on the ground floor with a rear garden; the second would be located at second floor level with 2x3 bed flats at 3rd floor level with large usable terraces. Whilst this percentage of family units is not policy compliant it has been agreed that this is the maximum reasonable amount that the scheme can viably provide. In addition taking into account the access requirements and the building envelope, 4 family units are what can fit comfortably into the scheme, having regard to the confines of the site and the numbers flats that can be accommodated at each respective floor without impacting on the loss of another flat. In addition due regard should be given to the fact that there are 3x 2 bed 4 person flats proposed as part of the scheme which could feasibly accommodate smaller family units and one of these units would also have direct access to the rear garden area.

- 6.6.9 In addition whilst it is not of specific relevance to this case it is noted that the scheme opposite at Number 10 Park Road has been approved with 4 family units out of the total of 18 on that scheme.

- 6.6.10 All factors taken into account it is considered that this submission overcomes the previous reason for refusal and that the proposed mix of units and standard of accommodation overall is considered acceptable.

6.7 *Private Amenity*

- 6.7.1 Since the implementation of the London Housing Supplementary Planning Document and the introduction of the councils draft Development Management Document, amenity space standards have been relaxed.
- 6.7.2 Policy DMD9 now specifies the requirements for private and communal amenity space for such developments.
- 6.7.3 Overall it is considered the private amenity provisions proposed are acceptable. Each of the proposed flats would be served by its own self-contained amenity areas. The ground floor flats would benefit from their own policy compliant rear gardens directly behind the proposed unit along with front facing terraces. In addition the remaining 11 flats would benefit from individual balconies all of which appear to be policy compliant having regard to DMD9.
- 6.7.4 All factors taken into account it is considered that the amenity provisions proposed is acceptable and in accordance with DMD9. Whilst there is no communal amenity space proposed, this is a result of the tight confines of the site. Nevertheless each individual unit is adequately served by its own private amenity space.

6.8 Traffic and Transportation

- 6.8.1 Due to the nature of the proposal the councils traffic and transportation department have been consulted on the application.
- 6.8.2 On the previous application there were initially reservations in relation to the lack of car parking on the site and the resultant impact that this would have with regard to on street capacity in the area. However upon re-assessment of the case transport officers have provided the following account.
- 6.8.3 Officers are also aware of the fact that the parking stress on the roads nearby is already very high. This is reflected in the local residents' request to the Council to introduce a controlled parking zone (CPZ) in the area. The risk of any parking overspill from the site could however be minimised by inclusion of an appropriate wording in the legal agreement preventing future occupants from applying for parking permits. The outcome of any public consultation cannot be predicted at this stage so there are risks associated with additional parking demand and its impact on parking pressure. The creation of additional public parking/kerbside space on street, by removal of three on site spaces would be a good way of addressing the issue, particularly supported with the introduction of mitigation measures contained in S106 (car club, pedestrian and cycle improvements etc.) which support sustainable travel and minimise car ownership. A car/parking free development could therefore be supported on this site.
- 6.8.4 Based on the advice as above traffic and transportation department have also recommended the following S106 contributions:
- £9,333.24 towards cycle route improvements;
 - £15,000 towards pedestrian environment improvements, particularly focused on access to Silver Street station, bus services in Fore Street and the junction of Park Avenue with Park Road;

- One three year car club membership per unit and driving credit of £100 per membership (there are two car club bays within walking distance of the site);
- Removal of redundant crossovers and footway resurfacing in front of the site.
- Ineligibility of the proposed units from obtaining parking permits within any future CPZ in the immediate adjoining area.

6.8.5 Based on this amended advice from traffic and transportation it is considered that the application can now be accepted from a traffic and transportation perspective subject to conditions and the above financial contributions being secured via a legal agreement associated with the site. It should be noted that the applicant has agreed to these highway S106 contributions and heads of terms.

6.9 S106 Contributions

Affordable Housing

6.9.1 Having regard to policies DMD1 and CP3 of the Core Strategy as the site is proposing 10 or more units (14) it should be complying with borough wide target of achieving 40% affordable housing and a mix of tenures to reflect a borough wide target of 70% social rent and affordable rent and 30% Intermediate. This would equate to 6 units on this site as affordable housing.

6.9.2 As part of the application submission the applicant has submitted a Viability Assessment that originally concluded that the scheme would not be viable to contribute on-site affordable units. This Viability Assessment has been assessed by the councils own independently appointed Viability Assessor and it has been agreed that the scheme cannot provide on-site units but that it can afford off site contributions of £85,000. This would be secured as part of a S106 legal agreement with the application.

Education Contributions

6.9.3 Having regard to policy CP46 of the Core Strategy and the councils S106 SPD, this application would also be required to provide education contributions towards local schools in the area.

6.9.4 This application proposes 3x1 bed, 7x2 bed and 4x3 bed units which would equate to a contribution of £42,435.67 towards off site education contributions. The applicant has agreed to these contributions which will be secured via the S106 Agreement.

Other S106 Contributions/ Head of Terms

6.9.5 Highways Contributions of £35,724 broken down as follows:

- £9,333.24 towards cycle route improvements;
- £15,000 towards pedestrian environment improvements, particularly focused on access to Silver Street station, bus services in Fore Street and the junction of Park Avenue with Park Road;
- One three year car club membership per unit and driving credit of £100 per membership (there are two car club bays within walking distance of the site);
- Removal of redundant crossovers and footway resurfacing in front of the site.

- Ineligibility of the proposed units from obtaining parking permits within any future CPZ in the immediate adjoining area. (Car free)
- 6.9.6 The S106 Monitoring fees would amount to £6372.76. The applicant has agreed to pay this fee.

6.10 Sustainable Design and Construction

Lifetime Homes

- 6.10.1 The London Plan and Core Strategy confirm that all new housing is to be built to Lifetime Homes' standards. This is to enable a cost-effective way of providing adaptable homes that are able to be adapted to meet changing needs.
- 6.10.2 The scheme appears to meet as much as possible the 16 criteria for Lifetime Homes. However, confirmation of this should be secured by condition.

Energy/Energy efficiency

- 6.10.3 The London Plan adopts a presumption that all developments will meet carbon dioxide emission reductions that will improve upon 2010 Building Regulations, leading to zero carbon residential buildings from 2016. Policy 5.2 establishes a target for 2010-2013 to be a 25% improvement over Part L of current Building Regulations
- 6.10.4 At this stage there has been no energy statement submitted to support the application. However it is considered these energy matters can be dealt with via planning conditions.

6.11 Mayors CIL

- 6.11.1 The size of the proposed development would be liable to a Community Infrastructure Levy contribution as the size exceeds 100 sq.m. The net gain of the new created floor area is 1093 sq.m , inclusive of the 14 units and the communal staircase area.
- 6.11.2 This would result in a CIL contribution of $1093 \text{ sq.m} \times £20 = £21,860 \times 274/223 = £26,859.37$.

7. Conclusion

- 7.1 It is considered that this development proposal is acceptable. It is considered to have an acceptable impact to the character and appearance of the site and surrounding Park Road area. It will provide for 4 additional family units and 14 additional residential units a whole in a relatively accessible part of the borough..
- 7.2 It is considered that its scale, bulk and appearance is acceptable and would be comparable and complement the approved building on the opposite side of Park Road. The proposed development would also have an acceptable impact onto adjoining neighbours amenities.
- 7.2 The proposed development would not have a significant impact to neighbours amenity or create unacceptable impact to highway function and safety.

7.2 In conclusion, officers consider the scheme to be acceptable subject to the conditions outlined as below and the completion of a suitable s106 Legal Agreement, it is recommended that planning permission is granted.

8. Recommendation

8.1 That planning permission be approved subject to the following conditions:

1. The development to which this permission relates must be begun not later than the expiration of three years beginning with the date of the decision notice.

Reason: To comply with the provisions of S.51 of the Planning & Compulsory Purchase Act 2004.

2. The development hereby permitted shall be carried out in accordance with the approved plans, as set out in the attached schedule which forms part of this notice.

Reason: For the avoidance of doubt and in the interests of proper planning.

3. That development shall not commence until a construction methodology has been submitted to and approved in writing by the Local Planning Authority. The construction methodology shall contain:

- a. arrangements for wheel cleaning;
- b. arrangements for the storage of materials;
- c. hours of work;
- d. arrangements for the securing of the site during construction;
- e. the arrangement for the parking of contractors' vehicles clear of the highway.
- f. The siting and design of any ancillary structures.
- g. A construction management plan written in accordance with the 'London Best Practice Guidance: The control of dust and emission from construction and demolition'.

The development shall be carried out in accordance with the approved construction methodology unless otherwise agreed in writing by the Local Planning Authority.

Reason: To ensure the implementation of the development does not lead to damage to the existing highway and to minimise disruption to neighbouring properties and the environment.

4. The development shall not commence until details of the external finishing materials to be used have been submitted to and approved in writing by the Local Planning Authority. The development shall be constructed in accordance with the approved details.

Reason: To ensure a satisfactory external appearance.

5. The development shall not commence until details of the surfacing materials to be used within the development including footpaths, access roads and parking areas and road markings have been submitted to and approved in

writing by the Local Planning Authority. The surfacing shall be carried out in accordance with the approved detail before the development is occupied or use commences.

Reason: To ensure that the development does not prejudice highway safety and a satisfactory appearance.

6. The development shall not commence until plans detailing the existing and proposed ground levels including the levels of any proposed buildings, roads and/or hard surfaced areas have been submitted to and approved in writing by the Local Planning Authority. The development shall be constructed in accordance with the approved details.

Reason: To ensure that levels have regard to the level of surrounding development, gradients and surface water drainage.

7. The site shall be enclosed in accordance with details to be submitted to and approved in writing by the Local Planning Authority. The means of enclosure shall be erected in accordance with the approved detail before the development is occupied.

Reason: To ensure satisfactory appearance and safeguard the privacy, amenity and safety of adjoining occupiers and the public and in the interests of highway safety.

8. The development shall not commence until details of trees, shrubs and grass to be planted on the site have been submitted to and approved in writing by the Local Planning Authority. The planting scheme shall be carried out in accordance with the approved details in the first planting season after completion or occupation of the development whichever is the sooner. Any planting which dies, becomes severely damaged or diseased within five years of planting shall be replaced with new planting in accordance with the approved details.

Reason: To provide a satisfactory appearance and ensure that the development does not prejudice highway safety.

9. The development shall not commence until details of refuse storage facilities including facilities for the recycling of waste to be provided within the development, in accordance with the London Borough of Enfield Waste and Recycling Planning Storage Guidance ENV 08/162, have been submitted to and approved in writing by the Local Planning Authority. The facilities shall be provided in accordance with the approved details before the development is occupied or use commences.

Reason: In the interests of amenity and the recycling of waste materials in support of the Boroughs waste reduction targets.

10. The development shall not commence until details of the siting, number and design of secure/covered cycle parking spaces have been submitted to and approved in writing by the Local Planning Authority. The approved details shall thereafter be installed and permanently retained for cycle parking.

Reason: To ensure the provision of cycle parking spaces in line with the Council's adopted standards.

11. All the units shall comply with Lifetime Home standards in accordance with details to be submitted to and approved in writing by the LPA. The development shall be carried out strictly in accordance with the details approved and shall be maintained thereafter.

Reason : To ensure that the development allows for future adaptability of the home to meet with the needs of future residents over their life time in accordance with Policy CP4 of the Core Strategy and Policy 3.5 of the London Plan 2011.

12. Prior to occupation of the development details of the security measures to serve the rear terrace assigned to Flat 1 shall be submitted to and approved in writing by the local planning authority.

Reason: In the interest of amenity and public safety.


13. The development shall not commence until a detailed 'Energy Statement' and relevant SAP calculations has been submitted and approved in writing by the Local Planning Authority. Submitted details will demonstrate the energy efficiency of the development and shall provide for no less than 11% total CO2 emissions arising from the operation of a development and its services over Part L of Building Regs 2010 ensuring that standard conversion factor indicate that natural gas is the primary heating fuel. The Energy Statement should outline how the reductions are achieved through the use of Fabric Energy Efficiency performance, energy efficient fittings, and the use of renewable technologies.

The development shall be carried out strictly in accordance with the details so approved and maintained as such thereafter. Following practical completion of works a final Energy Performance Certificate shall be submitted to an approved in writing by the Local Planning Authority. Where applicable, a Display Energy Certificate shall be submitted within 18 months following first occupation.


Reason: In the interest of sustainable development and to ensure that the Local Planning Authority may be satisfied that CO2 emission reduction targets are met in accordance with Policy CP20 of the Core Strategy, Policies 5.2, 5.3, 5.7 & 5.9 of the London Plan 2011 and the NPPF.

14. Following practical completion of works a final Energy Performance Certificate shall be submitted to an approved in writing by the Local Planning Authority prior to occupation of the development.

Reason: In the interest of sustainable development and to ensure that the Local Planning Authority may be satisfied that CO2 emission reduction targets are met in accordance with Policy CP20 of the Core Strategy, Policies 5.2, 5.3, 5.7 & 5.9 of the London Plan 2011 and the NPPF.



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any information to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



© Crown Copyright and database right 2015
 Ordnance Survey, License: 100048557
 Reproduction in whole or part is prohibited
 without the prior permission of Ordnance Survey



PROJECT: 2B Park Avenue
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015
 SCALE: 1:500 @ A2 / 1:1000 @ A4
 DRAWING NO: 15/15/01
 REVISION: REVISION
 REVISION DATE:


Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 All dimensions to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.

Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any permission to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any inconsistencies must be reported back to KS Design.
 All dimensions to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or used without prior expressed permission of KS Design.

PARK ROAD

PARK AVENUE




PROJECT: 2B Park Avenue
 SCALE: 1:100 @ A2 / 1:200 @ A4
 DRAWING NO.: 1031_03/PA
 REVISION: A
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015



Notes:
 Use figured dimensions only. Do not scale or use dimensions to be checked on site and any discrepancies must be reported to the architect immediately. This drawing is projected under copyright and shall not be reproduced without prior written permission of KS Design.


Retuse Bin Storage
 16.8 m²

28 Bicycle Spaces
 14.8 m²




Planning

Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any dimensions shown to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or used without prior expressed permission of KS Design.




Proposed First Floor Plan
 SCALE: 1:50 @ A2 (1:100 @ A4)
 DRAWING NO.: 103_03/11
 REVISION: A
 REVISION DATE: Sep. 2015

PROJECT: 28 Park Avenue
CLIENT: Paul Simon Homes Ltd.
DATE: March 2015




Planning

Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any dimensions shown to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any dimensions shown to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.





SCALE: 1:50 @ A2, 1:100 @ A4
 DRAWING NO.: A 03, 03/14
 REVISION: A
 REVISION DATE: Sep. 2015

PROJECT: 28 Park Avenue
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015




Planning

Notes:
Use figured dimensions only. Do not scale of this drawing.
All dimensions to be checked on site and any inconsistencies must be reported back to KS Design.
Any dimensions taken from the ground must be taken from the ground level.
This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system or used in any form without the expressed permission of KS Design.







Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any inconsistencies must be reported back to KS Design.
 Any dimension to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



Park Road Street Elevation




Park Avenue & Solomon Road Street Elevation



Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 Any dimensions shown to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



26 690
 Park Road




KS Design
 1 Colindale Avenue
 London, UK 900

PROJECT: 28 Park Avenue
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015


SCALE: 1:50 @ A2 / 1:100 @ A4
 DRAWING NO.: 103_0303A
 REVISION: A
 REVISION DATE: Sep. 2015

Proposed
 Front Elevation

Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any inconsistencies must be reported back to KS Design.
 All dimensions to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.



Proposed Rear Elevation

SCALE: 1:50 @ A2, 1:100 @ A4
 DRAWING NO. B 03, 03/15
 REVISION: B
 REVISION DATE: Oct. 2015


PROJECT: 28 Park Avenue
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015



Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any inconsistencies must be reported back to KS Design.
 Any dimensions shown to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or made without prior expressed permission of KS Design.





Proposed East Elevation

SCALE: 1:50 @ A2, 1:100 @ A4
 DRAWING NO: B 03/15/2015
 REVISION: B
 REVISION DATE: Oct. 2015

PROJECT: 2B Park Avenue
 CLIENT: Paul Simon Homes Ltd.
 DATE: March 2015



Planning



Notes:
 Use figured dimensions only. Do not scale of this drawing.
 All dimensions to be checked on site and any discrepancies must be reported back to KS Design.
 All dimensions to be taken from structural engineer's drawings.
 This drawing is protected under copyright and shall not be reproduced, stored in a retrieval system, or used without prior expressed permission of KS Design.

